

TEST CERTIFICATE

No. 120004062.03-01

Due to the examinations accomplished in the according with DIN EN ISO 17025 accredited testing laboratory for building hardware of the MPA NRW it is confirmed that

the building hardware Mortise locks „OneSystem Standard Commercial“
Wide-Style N1000 and N1050 as well as
Narrow-Style N1500 and N1550

of the manufacturer ASSA ABLOY Sicherheitstechnik GmbH
Bildstockstraße 20
72458 Albstadt

the durability test according
6.3.1.2. EN 12209: 2003 (D) 1.000.000 cycles
with

were tested and the requirements according 5.3 and 5.4 of
EN 12209: 2003 (D) are fulfill.

Door weight max. 300 kg

Dortmund, 13.07.2015

By order



Dipl.-Ing. H. Jansen
Head of test-laboratory



THIS TEST-CERTIFICATE COMPLIES 1 PAGE

This certificate based on the test reports no. 120004062.01 to no. 120004062.03

This document was originally written in German. In case of doubt the German

version shall prevail.

Notified Body Nr. 0432
Anerkannte PÜZ Stelle: NRW02



Deutsche
Akkreditierungsstelle
D-PL-11142-01-06